GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 1015

FIRE SAFETY CERTIFICATE

Certified that the Swiss Cottage School at Village Salahpur, Bijwasan, New Delhi-110061, comprised of ground plus two upper floors have already been issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2021/438 dated 06/07/2021. The premise was reinspected by the officer concerned of this department on 27/09/2024 in the presence of Sh. Mukesh Bhardwaj (Estate Officer) and found that the fire safety arrangements provided are in satisfactory working condition. Therefore, said premises/building have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Group-B (Educational) with effect from 14 / 10 /2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/10/2024 at New Delhi by

(ATUDICARG)
DIRECTOR
DELHI FIRE SERVICE

NEW

DELHI

S

Copy to: -

- 1. Principal, Swiss Cottage School at Village Salahpur, Bijwasan, New Delhi-110061
- 2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
- The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

- This FSC is not valid for the building blocks (A & B) each comprised of ground plus one
 upper floor. The school management has also submitted an undertaking regarding not to
 use these blocks for school activities without approval/NOC.
- 2. All the means of escape / entry / exit shall be kept free from any obstruction.
- 3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 4. All the staff members must know the correct method of operation of firefighting system.
- This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
- The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on www.dfs.delhigovt.nic.in.

MANAGER
SWISS COTTAGE SCHOOL
SALAHPUR NEW DELHI-110061
(OPP SECTOR-23 & PALAM VIHAR)

PH 05124-4259944, 55, T. FAX: 66

7.	Automatic fire detection and alarmin	u system	the state of the s	-
	Type of detector	NA NA	NA NA	NA NA
	Location of Main Panel	NA NA	NA NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA NA	NA
	Hooters' Location	NA	NA	NA
8.	MOEFA	+ NA	NA	NA
9.	Public Address System	NA NA	Provided	NA
10.	Automatic Sprinkler System	100000		RELIEF
10.		NA	T NA	NA NA
000	Basements	NA	NA	NA
877	Upper Floor	NA NA	NA	NA
	Sprinkler above false ceiling	147		
11.	Internal Hydrants	100 mm	100 mm	MR
	Size of riser/down-comer	The same of the sa	01 No.	MR
	Number of hydrants per floor	01 No.	02 Nos	MR
	Hose Box	02 Nos	02 (103	
12.	Yard Hydrants	NA	NA .	NA
	Total number of hydrants	NA NA	NA	NA
	Hose Box	NA .		
13.				
	Ground Level Discharge of main pump	NA	NA	NA
	> Head of main pump	NA	NA	NA
	> Number of main pumps	NA	NA	NA NA
Par le	> Jockey pump out put	NA	NA	NA NA
	> Jockey pump head	NA NA	NA NA	NA
Page 1	> Standby Pump out put > Standby Pump Head	NA NA	NA	NA
2.3	> Auto Staring/Manual stopping	NA	NA	NA
	> Pump House Access	NA	- NA	NA
	Terrace level			
	> Discharge of pump	450 LPM	450 LPM	MR
	> Head of the pump	35m	35m	MR
	> Power supply	Required	Provided	MR
	> Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
17.	Underground tank capacity	NA	NA	NA
	> Draw of connection	NA	NA	NA
	> Fire service inlet	NA	NA	NA
	> Access to tank	NA	NA	NA
	Overhead Tank capacity	5000 Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
10.	> Pressurization of Lift Shaft	NA	NA	NA
	> Pressurization of Lift lobby	NA NA	NA NA	NA
	> Communication in lift Car	NA NA	NA NA	NA NA
		NA NA		
	Fireman's Grounding Switch		NA NA	NA
17	> Lift Signage	NA NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area	N/A		
	> Total area	NA NA	NA	NA
Time and	Location	NA	NA	NA

	Name & address of the building	TON REPORT Swiss Cottag	ge School located	at Village	
		Salahpur, Bij	wasan, New Delh	1-110001	
2.	Type of Occupancy	Educational (Group-B (School)		
3.		Ground + 2 upper floors. Renewal			
4.	Type of Case				
5.	Details of previous NOC No.		138 dated 06/07/2	021	
6.	Fire Safety directives Letter No.	DOF Circular	dated 01/03/2011		
7.	Date of inspection	27/09/2024		The second	
8.		The Mark Assessment of the Control o			
9.	Name of the Inspecting Officer	ADO (SJ) Sh. Mukesh Bhardwaj (Estate Officer)			
	Name and designation of Officer from the building side	Sh. Mukesh B	iliaidwaj (Estato		
10.	Year of Construction	2007		=100 mon4	
11.	Applicant's letter No.	Outdoor Diary	No. 6600 dated 1	7/09/2024	
S.	Minimum standards on fire	Old NOC	Provided at site	Remarks MR/NMI	
No.	prevention and fire safety U/R 33	Requirement		MINIMA	
1.	Access of building		2 44 4	MR	
	Road width	06 mtr	Provided	MR	
	Gate width	4.5 mtr	Provided	NA NA	
	Width of internal road	NA	NA	INA	
2.	Number, width, Type & Arrangement	of exits			
	a. Number of staircases			1 100	
	Upper floors	2 Nos	2 Nos	MR	
	Basements	NA	NA	NA	
	b. Width of staircases				
	Upper floors	1.5m / 0.75m		MR (old case)	
13 11/2	Basements	NA	NA	NA	
	c. Protection of exits				
	Fire check door	NA	NA	NA	
	Pressurization	NA	NA	NA	
	d. No of continuous staircase to terrace	Required	01 No.	MR	
	e. Width of Corridor	1.5 mtr	1.78 mtr	MR	
	f. Door Size	lm	0.98 – 1 mtr	MR	
3.	Compartmentation			- Table	
	Fire check door	NA	NA	NA	
	Sealing of electrical shafts	NA	NA	NA	
	Fire Rating of shaft door	NA	NA	NA	
	Water Curtain	NA	NA	NA	
	Fire Dampers	NA	NA	NA	
4.	Smoke managements System				
	Basements	NA	NA	NA	
	Upper floors	12 ACPH	Natural Ventilation	MR	
5.	Fire Extinguishers				
	Total numbers	15 Nos	15 Nos	MR	
	Types	ABC/CO ₂	ABC & CO ₂	MR	
		ISI Marked	Provided	MR	
	ISI marking	ALSE TYRONING II			
6.	First-Aid Hose Reels		2		
6.		02 Nos 30m	Provided Provided	MR MR	

19.	Fire Control Koom			1
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel > PA System Panel > Battery backup > Building Floor Plans	NA	NA	NA
		NA	NA NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any; Two blocks (A & B) each comprised of	NA	NA	NA

Note: Two blocks (A & B) each comprised of ground plus one upper floor only was being used for school activities (day care/play school). The school management has submitted an undertaking that these blocks shall not be used for school activities without prior approval in future.

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection. The shorteness communicated vide this department letter No. F6/DFS/MS/School/2024/SZ/427 dated 10/07/2024 found complied,

Keeping in view of the deemed compliance of the scientificate standards on fire prevention and fire safety measures as required under the safety water that safety certificate issued vide letter No. F.6/DFS/MS/2021/438 dated 06/07/2021, tenested makes rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

š€

Accordingly, DFA is put up for approval and signature please.

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

Multiply

Obs a revened Case width of Opersease
as per Do & Circular Loled 01.03.2011.

resolanted puerse.

Spuna

Of 10.14

Description:


Manue: Santosh Kumar
Designation: ADO (SJ)

Multiply

Multiply

Multiply

Personanted puerse.



No. F.6/DFS/MS/School/2024/SZ/ 1015

FIRE SAFETY CERTIFICATE

Certified that the Swiss Cottage School at Village Salahpur, Bijwasan, New Delhi-110061, comprised of ground plus two upper floors have already been issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2021/438 dated 06/07/2021. The premise was reinspected by the officer concerned of this department on 27/09/2024 in the presence of Sh. Mukesh Bhardwaj (Estate Officer) and found that the fire safety arrangements provided are in satisfactory working condition. Therefore, said premises/building have deemed complied with the fire prevention and fire safety requirement in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Group-B (Educational) with effect from 14 / 10 /2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/10/2024 at New Delhi by

(ATUNGARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Principal, Swiss Cottage School at Village Salahpur, Bijwasan, New Delhi-110061

2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

3. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

- This FSC is not valid for the building blocks (A & B) each comprised of ground plus one
 upper floor. The school management has also submitted an undertaking regarding not to
 use these blocks for school activities without approval/NOC.
- 2. All the means of escape / entry / exit shall be kept free from any obstruction.
- 3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 4. All the staff members must know the correct method of operation of firefighting system.
- This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
- 6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on www.dfs.delhigovt.nic.in.

SWISS COTTAGE SCHOOL SWISS COTTAGE SCHOOL SALAHPUR, NEW DELHI-110061